



Alliance Technical Group - Akron
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211
Website: <http://www.settek.com>

April 20, 2026

Kevin Summerville
Columbiana County Health District
7360 SR 45
P.O. Box 309
Lisbon, OH 44432
TEL:
FAX:

RE: Extended Sampling

Dear Kevin Summerville:

Order No.: 26040946

Alliance Technical Group - Akron received 3 sample(s) on 4/13/2026 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative.

Quality control data is within laboratory defined or method specified acceptance limits except where noted.

If you have any questions regarding these tests results, please feel free to call the laboratory.

Sincerely,

A handwritten signature in black ink that reads "Sarah MacGillivray". The signature is fluid and cursive, with a long, sweeping underline that extends to the right.

Sarah MacGillivray

Project Manager

3310 Win St.
Cuyahoga Falls, Ohio 44223

Arkansas 88-0735, California 2943, Colorado, Connecticut PH-0828, Florida NELAC E87688, Idaho OH00923, Illinois 200061, Indiana C-OH-13, ISO/IEC 17025:2017 119125 L22-544, Kansas E-10347, Kentucky (Underground Storage Tank) 3, Kentucky 90146, Maryland 339, Michigan 9988, Minnesota 1780279, Nevada OH009232020-1, New Hampshire 2996, New Jersey OH006, New York 11777, North Carolina 39705 and 631, North Dakota R-201, Ohio DW, Ohio VAP CL0052, Oklahoma 2019-155, Oregon OH200001, Pennsylvania 68-01335, Rhode Island LA000317, South Carolina 92016001, Texas T104704466-19-16, Utah OH009232020-12, Virginia VELAP 10381, West Virginia 9957C



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Workorder Sample Summary

WO#: 26040946
 20-Apr-26

CLIENT: Columbiana County Health District
Project: Extended Sampling

| Lab SampleID | Client Sample ID | Tag No | Date Collected | Date Received | Matrix |
|--------------|------------------|--------|-----------------------|----------------------|----------------|
| 26040946-001 | ES-091 | | 4/10/2026 10:20:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-001 | ES-091 | | 4/10/2026 10:20:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-001 | ES-091 | | 4/10/2026 10:20:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-001 | ES-091 | | 4/10/2026 10:20:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-002 | FB-091 | | 4/10/2026 10:15:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-002 | FB-091 | | 4/10/2026 10:15:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-002 | FB-091 | | 4/10/2026 10:15:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-002 | FB-091 | | 4/10/2026 10:15:00 AM | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-003 | Trip Blank | | 4/10/2026 | 4/13/2026 3:15:00 PM | Drinking Water |
| 26040946-003 | Trip Blank | | 4/10/2026 | 4/13/2026 3:15:00 PM | Drinking Water |



Alliance Technical Group - Akron
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Case Narrative

WO#: 26040946
Date: 4/20/2026

CLIENT: Columbiana County Health District
Project: Extended Sampling

WorkOrder Narrative:

26040946: This report in its entirety consists of the following documents: Cover Letter, Case Narrative, Analytical Results, QC Summary Report, Applicable Accreditation Information, Chain-of-Custody, Cooler Receipt Form, and other applicable forms as necessary. All documents contain the Alliance Technical Group Work Order Number assigned to this report.

Alliance Technical Group holds the accreditations/certifications listed at the bottom of the cover letter that may or may not pertain to this report. Please refer to the "Accreditation Program Analytes Report" for accredited analytes list.

The information contained in this analytical report is the sole property of Alliance Technical Group and that of the customer. It cannot be reproduced in any form without the consent of Alliance Technical Group or the customer for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Alliance Technical Group is not responsible for use or interpretation of the data included herein.

All results for solid samples are reported on an "as received" or "wet weight" basis unless indicated as "dry weight" using the "-dry" designation on the reporting units.

This report is believed to meet all of the requirements of the accrediting agency, where applicable. Any comments or problems with the analytical events associated with this report are noted below.

WorkOrder Comments:

26040946: The lab does not routinely spike for 2-Butoxyethanol; this compound is included in the instrument initial calibration and initial calibration verification.

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: 26040946

Date Reported: 4/20/2026

Lab ID: 26040946-001

Collection Date: 4/10/2026 10:20:00 AM

Client Sample ID ES-091

Matrix: DRINKING WATER

| Analysis | Result | MDL | PQL | Qual | Units | Dilution | Batch | Date Analyzed |
|---|--------|---------|--------|------|------------------|----------|--------------------------------------|----------------------|
| SYNTHETIC ORGANIC COMPOUNDS BY GC/MS (EPA 525.3) | | | | | EPA 525.3 | | EPA 525.3 Analyst: SAM | |
| 1-Methylnaphthalene | ND | 0.00360 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| 2-Methylnaphthalene | ND | 0.00528 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Acenaphthene | ND | 0.00468 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Acenaphthylene | ND | 0.00321 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Anthracene | ND | 0.00943 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Benz(a)anthracene | ND | 0.00390 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Benzo(a)pyrene | ND | 0.00389 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Benzo(b)fluoranthene | ND | 0.00456 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Benzo(g,h,i)perylene | ND | 0.00412 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Benzo(k)fluoranthene | ND | 0.00515 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Chrysene | ND | 0.00436 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Dibenz(a,h)anthracene | ND | 0.00362 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Fluoranthene | ND | 0.0305 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Fluorene | ND | 0.00381 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Indeno(1,2,3-cd)pyrene | ND | 0.00433 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Naphthalene | ND | 0.0454 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Phenanthrene | ND | 0.00387 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Pyrene | ND | 0.00636 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Surr: 1,3-Dimethyl-2-nitrobenzene | 90.6 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Surr: Benzo(a)pyrene-d12 | 92.0 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 8:28:00 PM |
| Surr: Triphenyl phosphate | 104 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 8:28:00 PM |
| SVOC BY 8270E | | | | | EPA 8270E | | EPA 3510 Analyst: SAM | |
| 2-Butoxyethanol | ND | 0.176 | 29.1 | | µg/L | 1 | 95596 | 4/15/2026 3:13:00 AM |
| Surr: Nitrobenzene-d5 | 86.5 | | 10-130 | | %Rec | 1 | 95596 | 4/15/2026 3:13:00 AM |
| Surr: 2-Fluorobiphenyl | 102 | | 10-130 | | %Rec | 1 | 95596 | 4/15/2026 3:13:00 AM |
| Surr: p-Terphenyl-d14 | 96.0 | | 20-181 | | %Rec | 1 | 95596 | 4/15/2026 3:13:00 AM |
| VOC-GC/MS (524.2) | | | | | EPA 524.2 | | Analyst: EC | |
| 1,1-Dichloropropene | ND | 0.112 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| 1,2,4-Trimethylbenzene | ND | 0.172 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Benzene | ND | 0.0967 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Ethylbenzene | ND | 0.192 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| m,p-Xylene | ND | 0.422 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Naphthalene | ND | 0.206 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| o-Xylene | ND | 0.211 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Toluene | ND | 0.160 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Vinyl chloride | ND | 0.0841 | 0.200 | | µg/L | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Surr: 1,2-Dichlorobenzene-d4 | 91.8 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 5:52:00 PM |
| Surr: 4-Bromofluorobenzene | 88.3 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 5:52:00 PM |

Qualifiers:

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 R RPD outside accepted recovery limits
 W Sample container temperature is out of limit as specified at testcode

E Value above quantitation range
 M Manual Integration used to determine area response
 PL Permit Limit
 RL Reporting Detection Limit
 J Analyte detected below quantitation limits



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: **26040946**

Date Reported: **4/20/2026**

Lab ID: 26040946-001

Collection Date: 4/10/2026 10:20:00 AM

Client Sample ID ES-091

Matrix: DRINKING WATER

| Analysis | Result | MDL | PQL | Qual | Units | Dilution | Batch | Date Analyzed |
|-----------------------------|--------|-------|--------|------|------------------|----------|-------------------|-----------------------|
| VOC BY GC/MS (8260D) | | | | | EPA 8260D | | EPA 5030 B | Analyst: FF |
| 2-Ethylhexyl acrylate | ND | 0.114 | 0.500 | | µg/L | 1 | R234329 | 4/14/2026 10:12:00 PM |
| n-Butyl acrylate | ND | 0.114 | 1.00 | | µg/L | 1 | R234329 | 4/14/2026 10:12:00 PM |
| Surr: 4-Bromofluorobenzene | 99.0 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:12:00 PM |
| Surr: Dibromofluoromethane | 102 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:12:00 PM |
| Surr: Toluene-d8 | 100 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:12:00 PM |

Qualifiers:

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 R RPD outside accepted recovery limits
 W Sample container temperature is out of limit as specified at testcode

E Value above quantitation range
 M Manual Integration used to determine area response
 PL Permit Limit
 RL Reporting Detection Limit
 J Analyte detected below quantitation limits



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: 26040946

Date Reported: 4/20/2026

Lab ID: 26040946-002

Collection Date: 4/10/2026 10:15:00 AM

Client Sample ID FB-091

Matrix: DRINKING WATER

| Analysis | Result | MDL | PQL | Qual | Units | Dilution | Batch | Date Analyzed |
|---|--------|---------|--------|------|------------------|----------|------------------|----------------------|
| SYNTHETIC ORGANIC COMPOUNDS BY GC/MS (EPA 525.3) | | | | | EPA 525.3 | | EPA 525.3 | Analyst: SAM |
| 1-Methylnaphthalene | ND | 0.00360 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| 2-Methylnaphthalene | ND | 0.00528 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Acenaphthene | ND | 0.00468 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Acenaphthylene | ND | 0.00321 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Anthracene | ND | 0.00943 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Benz(a)anthracene | ND | 0.00390 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Benzo(a)pyrene | ND | 0.00389 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Benzo(b)fluoranthene | ND | 0.00456 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Benzo(g,h,i)perylene | ND | 0.00412 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Benzo(k)fluoranthene | ND | 0.00515 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Chrysene | ND | 0.00436 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Dibenz(a,h)anthracene | ND | 0.00362 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Fluoranthene | ND | 0.0305 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Fluorene | ND | 0.00381 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Indeno(1,2,3-cd)pyrene | ND | 0.00433 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Naphthalene | ND | 0.0454 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Phenanthrene | ND | 0.00387 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Pyrene | ND | 0.00636 | 0.0990 | | µg/L | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Surr: 1,3-Dimethyl-2-nitrobenzene | 87.8 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Surr: Benzo(a)pyrene-d12 | 93.2 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 9:01:00 PM |
| Surr: Triphenyl phosphate | 106 | | 70-130 | | %Rec | 1 | 95649 | 4/16/2026 9:01:00 PM |
| SVOC BY 8270E | | | | | EPA 8270E | | EPA 3510 | Analyst: SAM |
| 2-Butoxyethanol | ND | 0.181 | 30.0 | | µg/L | 1 | 95596 | 4/15/2026 3:47:00 AM |
| Surr: Nitrobenzene-d5 | 79.8 | | 10-130 | | %Rec | 1 | 95596 | 4/15/2026 3:47:00 AM |
| Surr: 2-Fluorobiphenyl | 96.4 | | 10-130 | | %Rec | 1 | 95596 | 4/15/2026 3:47:00 AM |
| Surr: p-Terphenyl-d14 | 90.4 | | 20-181 | | %Rec | 1 | 95596 | 4/15/2026 3:47:00 AM |
| VOC-GC/MS (524.2) | | | | | EPA 524.2 | | | Analyst: EC |
| 1,1-Dichloropropene | ND | 0.112 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| 1,2,4-Trimethylbenzene | ND | 0.172 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Benzene | ND | 0.0967 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Ethylbenzene | ND | 0.192 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| m,p-Xylene | ND | 0.422 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Naphthalene | ND | 0.206 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| o-Xylene | ND | 0.211 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Toluene | ND | 0.160 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Vinyl chloride | ND | 0.0841 | 0.200 | | µg/L | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Surr: 1,2-Dichlorobenzene-d4 | 91.9 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 6:20:00 PM |
| Surr: 4-Bromofluorobenzene | 91.5 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 6:20:00 PM |

Qualifiers:

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 R RPD outside accepted recovery limits
 W Sample container temperature is out of limit as specified at testcode

E Value above quantitation range
 M Manual Integration used to determine area response
 PL Permit Limit
 RL Reporting Detection Limit
 J Analyte detected below quantitation limits



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: 26040946

Date Reported: 4/20/2026

Lab ID: 26040946-002

Collection Date: 4/10/2026 10:15:00 AM

Client Sample ID FB-091

Matrix: DRINKING WATER

| Analysis | Result | MDL | PQL | Qual | Units | Dilution | Batch | Date Analyzed |
|-----------------------------|--------|-------|--------|------|------------------|----------|-------------------|-----------------------|
| VOC BY GC/MS (8260D) | | | | | EPA 8260D | | EPA 5030 B | Analyst: FF |
| 2-Ethylhexyl acrylate | ND | 0.114 | 0.500 | | µg/L | 1 | R234329 | 4/14/2026 10:39:00 PM |
| n-Butyl acrylate | ND | 0.114 | 1.00 | | µg/L | 1 | R234329 | 4/14/2026 10:39:00 PM |
| Surr: 4-Bromofluorobenzene | 99.1 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:39:00 PM |
| Surr: Dibromofluoromethane | 101 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:39:00 PM |
| Surr: Toluene-d8 | 102 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 10:39:00 PM |

Qualifiers:

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 R RPD outside accepted recovery limits
 W Sample container temperature is out of limit as specified at testcode

E Value above quantitation range
 M Manual Integration used to determine area response
 PL Permit Limit
 RL Reporting Detection Limit
 J Analyte detected below quantitation limits



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: 26040946

Date Reported: 4/20/2026

Lab ID: 26040946-003

Collection Date: 4/10/2026

Client Sample ID Trip Blank

Matrix: DRINKING WATER

| Analysis | Result | MDL | PQL | Qual | Units | Dilution | Batch | Date Analyzed |
|------------------------------|--------|--------|--------|------------------|-------|-------------------------------|---------|-----------------------|
| VOC-GC/MS (524.2) | | | | EPA 524.2 | | | | Analyst: EC |
| 1,1-Dichloropropene | ND | 0.112 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| 1,2,4-Trimethylbenzene | ND | 0.172 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Benzene | ND | 0.0967 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Ethylbenzene | ND | 0.192 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| m,p-Xylene | ND | 0.422 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Naphthalene | ND | 0.206 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| o-Xylene | ND | 0.211 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Toluene | ND | 0.160 | 0.500 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Vinyl chloride | ND | 0.0841 | 0.200 | | µg/L | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Surr: 1,2-Dichlorobenzene-d4 | 88.1 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 6:48:00 PM |
| Surr: 4-Bromofluorobenzene | 87.2 | | 70-130 | | %Rec | 1 | R234312 | 4/14/2026 6:48:00 PM |
| VOC BY GC/MS (8260D) | | | | EPA 8260D | | EPA 5030 B Analyst: FF | | |
| 2-Ethylhexyl acrylate | ND | 0.114 | 0.500 | | µg/L | 1 | R234329 | 4/14/2026 11:07:00 PM |
| n-Butyl acrylate | ND | 0.114 | 1.00 | | µg/L | 1 | R234329 | 4/14/2026 11:07:00 PM |
| Surr: 4-Bromofluorobenzene | 97.3 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 11:07:00 PM |
| Surr: Dibromofluoromethane | 102 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 11:07:00 PM |
| Surr: Toluene-d8 | 101 | | 70-130 | | %Rec | 1 | R234329 | 4/14/2026 11:07:00 PM |

Qualifiers:

| | | | |
|----|---|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded | M | Manual Integration used to determine area response |
| ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit |
| W | Sample container temperature is out of limit as specified at testcode | J | Analyte detected below quantitation limits |



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: http://www.settek.com

QC SUMMARY REPORT

WO#: 26040946

20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: 95596

| Sample ID: MB-95596 | SampType: MBLK | TestCode: SVOC-MSTR | Units: µg/L | Prep Date: 4/13/2026 | RunNo: 234281 | | | | | | |
|----------------------------|------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95596 | TestNo: SW8270 | SW3510C | Analysis Date: 4/14/2026 | SeqNo: 6145080 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 2-Butoxyethanol | ND | 30.0 | | 0 | 0 | | | | | | |
| Surr: 2-Fluorophenol | 0.0211 | | 0.05000 | | 42.2 | 10 | 130 | | | | |
| Surr: Phenol-d6 | 0.0139 | | 0.05000 | | 27.8 | 10 | 130 | | | | |
| Surr: Nitrobenzene-d5 | 0.0341 | | 0.05000 | | 68.3 | 10 | 130 | | | | |
| Surr: 2,4,6-Tribromophenol | 0.0414 | | 0.05000 | | 82.7 | 16 | 151 | | | | |
| Surr: 2-Fluorobiphenyl | 0.0363 | | 0.05000 | | 72.7 | 10 | 130 | | | | |
| Surr: p-Terphenyl-d14 | 0.0465 | | 0.05000 | | 92.9 | 20 | 181 | | | | |

| Sample ID: LCS-95596 | SampType: LCS | TestCode: SVOC-MSTR | Units: %Rec | Prep Date: 4/13/2026 | RunNo: 234281 | | | | | | |
|-----------------------------|------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95596 | TestNo: SW8270 | SW3510C | Analysis Date: 4/14/2026 | SeqNo: 6145081 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Surr: 2-Fluorophenol | 0.0240 | | 0.05000 | | 48.0 | 10 | 130 | | | | |
| Surr: Phenol-d6 | 0.0162 | | 0.05000 | | 32.4 | 10 | 130 | | | | |
| Surr: Nitrobenzene-d5 | 0.0385 | | 0.05000 | | 77.1 | 10 | 130 | | | | |
| Surr: 2,4,6-Tribromophenol | 0.0478 | | 0.05000 | | 95.7 | 16 | 151 | | | | |
| Surr: 2-Fluorobiphenyl | 0.0407 | | 0.05000 | | 81.3 | 10 | 130 | | | | |
| Surr: p-Terphenyl-d14 | 0.0480 | | 0.05000 | | 96.0 | 20 | 181 | | | | |

| Sample ID: LCSD-95596 | SampType: LCSD | TestCode: SVOC-MSTR | Units: %Rec | Prep Date: 4/13/2026 | RunNo: 234281 | | | | | | |
|------------------------------|------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95596 | TestNo: SW8270 | SW3510C | Analysis Date: 4/14/2026 | SeqNo: 6145082 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

Qualifiers:

| | | | | | |
|---|--|----|--------------------------------|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: 95596

| Sample ID: LCSD-95596 | SampType: LCSD | TestCode: SVOC-MSTR | Units: %Rec | Prep Date: 4/13/2026 | RunNo: 234281 | | | | | | |
|------------------------------|------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95596 | TestNo: SW8270 | SW3510C | Analysis Date: 4/14/2026 | SeqNo: 6145082 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Surr: 2-Fluorophenol | 0.0223 | | 0.05000 | | 44.6 | 10 | 130 | | 0 | | |
| Surr: Phenol-d6 | 0.0147 | | 0.05000 | | 29.4 | 10 | 130 | | 0 | | |
| Surr: Nitrobenzene-d5 | 0.0415 | | 0.05000 | | 83.0 | 10 | 130 | | 0 | | |
| Surr: 2,4,6-Tribromophenol | 0.0443 | | 0.05000 | | 88.6 | 16 | 151 | | 0 | | |
| Surr: 2-Fluorobiphenyl | 0.0430 | | 0.05000 | | 86.0 | 10 | 130 | | 0 | | |
| Surr: p-Terphenyl-d14 | 0.0485 | | 0.05000 | | 97.1 | 20 | 181 | | 0 | | |

| | | | | | | |
|--------------------|---|--|----|--------------------------------|----|--|
| Qualifiers: | B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceede |
| | M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| | R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| | J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: 95596

| Sample ID: MB-95596 | SampType: MBLK | TestCode: SVOC-EXTR | Units: µg/L | Prep Date: 4/13/2026 | RunNo: 234387 | | | | | | |
|----------------------------|------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95596 | TestNo: SW8270 | SW3510C | Analysis Date: 4/15/2026 | SeqNo: 6147463 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 2-Butoxyethanol | ND | 30.0 | | 0 | 0 | | | | | | QC- |
| Surr: 2-Fluorophenol | 0 | | 0.05000 | | 0 | 10 | 130 | | | | S |
| Surr: Phenol-d6 | 0 | | 0.05000 | | 0 | 10 | 130 | | | | S |
| Surr: Nitrobenzene-d5 | 0 | | 0.05000 | | 0 | 10 | 130 | | | | S |
| Surr: 2,4,6-Tribromophenol | 0 | | 0.05000 | | 0 | 19 | 151 | | | | S |
| Surr: 2-Fluorobiphenyl | 0 | | 0.05000 | | 0 | 10 | 130 | | | | S |
| Surr: p-Terphenyl-d14 | 0 | | 0.05000 | | 0 | 20 | 181 | | | | S |

| | | | | | | |
|--------------------|---|--|----|--------------------------------|----|--|
| Qualifiers: | B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceede |
| | M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| | R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| | J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: 95649

| Sample ID: MB-95649 | SampType: MBLK | TestCode: SVOC_DW(5) | Units: µg/L | Prep Date: 4/14/2026 | RunNo: 234513 | | | | | | |
|-----------------------------------|------------------------|-----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95649 | TestNo: E525 | 525 | Analysis Date: 4/16/2026 | SeqNo: 6150700 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1-Methylnaphthalene | ND | 0.100 | | | | | | | | | |
| 2-Methylnaphthalene | ND | 0.100 | | | | | | | | | |
| Acenaphthene | ND | 0.100 | | | | | | | | | |
| Acenaphthylene | ND | 0.100 | | | | | | | | | |
| Anthracene | ND | 0.100 | | | | | | | | | |
| Benz(a)anthracene | ND | 0.100 | | | | | | | | | |
| Benzo(a)pyrene | ND | 0.100 | | | | | | | | | |
| Benzo(b)fluoranthene | ND | 0.100 | | | | | | | | | |
| Benzo(g,h,i)perylene | ND | 0.100 | | | | | | | | | |
| Benzo(k)fluoranthene | ND | 0.100 | | | | | | | | | |
| Chrysene | ND | 0.100 | | | | | | | | | |
| Dibenz(a,h)anthracene | ND | 0.100 | | | | | | | | | |
| Fluoranthene | ND | 0.100 | | | | | | | | | |
| Fluorene | ND | 0.100 | | | | | | | | | |
| Indeno(1,2,3-cd)pyrene | ND | 1.00 | | | | | | | | | |
| Naphthalene | ND | 0.100 | | | | | | | | | |
| Phenanthrene | ND | 0.100 | | | | | | | | | |
| Pyrene | ND | 0.100 | | | | | | | | | |
| Surr: 1,3-Dimethyl-2-nitrobenzene | 4.18 | | 5.000 | | 83.6 | 70 | 130 | | | | |
| Surr: Benzo(a)pyrene-d12 | 4.71 | | 5.000 | | 94.2 | 70 | 130 | | | | |
| Surr: Triphenyl phosphate | 5.41 | | 5.000 | | 108 | 70 | 130 | | | | |

| | | | | | | |
|--------------------|---|--|----|--------------------------------|----|--|
| Qualifiers: | B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| | M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| | R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| | J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: http://www.settek.com

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: 95649

| Sample ID: LCS-95649 | SampType: LCS | TestCode: SVOC_DW(5) | Units: µg/L | Prep Date: 4/14/2026 | RunNo: 234513 | | | | | | |
|-----------------------------------|-----------------|----------------------|-------------|--------------------------|----------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: 95649 | TestNo: E525 | 525 | Analysis Date: 4/16/2026 | SeqNo: 6150702 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1-Methylnaphthalene | 4.25 | 0.100 | 5.000 | 0 | 85.0 | 70 | 130 | | | | |
| 2-Methylnaphthalene | 4.33 | 0.100 | 5.000 | 0 | 86.6 | 70 | 130 | | | | |
| Acenaphthene | 4.34 | 0.100 | 5.000 | 0 | 86.8 | 70 | 130 | | | | |
| Acenaphthylene | 4.38 | 0.100 | 5.000 | 0 | 87.6 | 70 | 130 | | | | |
| Anthracene | 4.64 | 0.100 | 5.000 | 0 | 92.8 | 70 | 130 | | | | |
| Benz(a)anthracene | 4.72 | 0.100 | 5.000 | 0 | 94.4 | 70 | 130 | | | | |
| Benzo(a)pyrene | 4.35 | 0.100 | 5.000 | 0 | 87.0 | 70 | 130 | | | | |
| Benzo(b)fluoranthene | 4.38 | 0.100 | 5.000 | 0 | 87.6 | 70 | 130 | | | | |
| Benzo(g,h,i)perylene | 4.44 | 0.100 | 5.000 | 0 | 88.8 | 70 | 130 | | | | |
| Benzo(k)fluoranthene | 4.78 | 0.100 | 5.000 | 0 | 95.6 | 70 | 130 | | | | |
| Chrysene | 5.15 | 0.100 | 5.000 | 0 | 103 | 70 | 130 | | | | |
| Dibenz(a,h)anthracene | 4.22 | 0.100 | 5.000 | 0 | 84.4 | 70 | 130 | | | | |
| Fluoranthene | 4.76 | 0.100 | 5.000 | 0 | 95.2 | 70 | 130 | | | | |
| Fluorene | 4.59 | 0.100 | 5.000 | 0 | 91.8 | 70 | 130 | | | | |
| Indeno(1,2,3-cd)pyrene | 4.29 | 1.00 | 5.000 | 0 | 85.8 | 70 | 130 | | | | m |
| Naphthalene | 4.09 | 0.100 | 5.000 | 0 | 81.8 | 70 | 130 | | | | |
| Phenanthrene | 4.64 | 0.100 | 5.000 | 0 | 92.8 | 70 | 130 | | | | |
| Pyrene | 4.77 | 0.100 | 5.000 | 0 | 95.4 | 70 | 130 | | | | |
| Surr: 1,3-Dimethyl-2-nitrobenzene | 4.29 | | 5.000 | | 85.8 | 70 | 130 | | | | |
| Surr: Benzo(a)pyrene-d12 | 4.45 | | 5.000 | | 89.0 | 70 | 130 | | | | |
| Surr: Triphenyl phosphate | 4.84 | | 5.000 | | 96.8 | 70 | 130 | | | | |

| | | | | | | |
|--------------------|---|--|----|--------------------------------|----|--|
| Qualifiers: | B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| | M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| | R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| | J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: http://www.settek.com

QC SUMMARY REPORT

WO#: 26040946

20-Apr-26

Client: Columbiana County Health District

Project: Extended Sampling

BatchID: 95649

| Sample ID: LCS D-95649 | SampType: LCS D | TestCode: SVOC_DW(5) | Units: µg/L | Prep Date: 4/14/2026 | RunNo: 234513 | | | | | | |
|---------------------------------|------------------------|-----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|-------|----------|------|
| Client ID: BatchQC | Batch ID: 95649 | TestNo: E525 | 525 | Analysis Date: 4/16/2026 | SeqNo: 6150704 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1-Methylnaphthalene | 4.04 | 0.100 | 5.000 | 0 | 80.8 | 70 | 130 | 4.250 | 5.07 | 30 | |
| 2-Methylnaphthalene | 4.16 | 0.100 | 5.000 | 0 | 83.2 | 70 | 130 | 4.330 | 4.00 | 30 | |
| Acenaphthene | 4.20 | 0.100 | 5.000 | 0 | 84.0 | 70 | 130 | 4.340 | 3.28 | 30 | |
| Acenaphthylene | 4.22 | 0.100 | 5.000 | 0 | 84.4 | 70 | 130 | 4.380 | 3.72 | 30 | |
| Anthracene | 4.53 | 0.100 | 5.000 | 0 | 90.6 | 70 | 130 | 4.640 | 2.40 | 30 | |
| Benz(a)anthracene | 4.56 | 0.100 | 5.000 | 0 | 91.2 | 70 | 130 | 4.720 | 3.45 | 30 | |
| Benzo(a)pyrene | 4.15 | 0.100 | 5.000 | 0 | 83.0 | 70 | 130 | 4.350 | 4.71 | 30 | |
| Benzo(b)fluoranthene | 4.21 | 0.100 | 5.000 | 0 | 84.2 | 70 | 130 | 4.380 | 3.96 | 30 | |
| Benzo(g,h,i)perylene | 4.17 | 0.100 | 5.000 | 0 | 83.4 | 70 | 130 | 4.440 | 6.27 | 30 | |
| Benzo(k)fluoranthene | 4.56 | 0.100 | 5.000 | 0 | 91.2 | 70 | 130 | 4.780 | 4.71 | 30 | |
| Chrysene | 4.98 | 0.100 | 5.000 | 0 | 99.6 | 70 | 130 | 5.150 | 3.36 | 30 | |
| Dibenz(a,h)anthracene | 3.98 | 0.100 | 5.000 | 0 | 79.6 | 70 | 130 | 4.220 | 5.85 | 30 | |
| Fluoranthene | 4.71 | 0.100 | 5.000 | 0 | 94.2 | 70 | 130 | 4.760 | 1.06 | 30 | |
| Fluorene | 4.46 | 0.100 | 5.000 | 0 | 89.2 | 70 | 130 | 4.590 | 2.87 | 30 | |
| Indeno(1,2,3-cd)pyrene | 4.04 | 1.00 | 5.000 | 0 | 80.8 | 70 | 130 | 4.290 | 6.00 | 30 | m |
| Naphthalene | 3.89 | 0.100 | 5.000 | 0 | 77.8 | 70 | 130 | 4.090 | 5.01 | 30 | |
| Phenanthrene | 4.60 | 0.100 | 5.000 | 0 | 92.0 | 70 | 130 | 4.640 | 0.866 | 30 | |
| Pyrene | 4.73 | 0.100 | 5.000 | 0 | 94.6 | 70 | 130 | 4.770 | 0.842 | 30 | |
| Surr: 1,3-Dimethyl-2-nitrobe... | 4.05 | | 5.000 | | 81.0 | 70 | 130 | | 0 | 30 | |
| Surr: Benzo(a)pyrene-d12 | 4.09 | | 5.000 | | 81.8 | 70 | 130 | | 0 | 30 | |
| Surr: Triphenyl phosphate | 4.70 | | 5.000 | | 94.0 | 70 | 130 | | 0 | 30 | |

| | | | |
|--------------------|--|----------------------------------|--|
| Qualifiers: | B Analyte detected in the associated Method Blank | E Value above quantitation range | H Holding times for preparation or analysis exceede |
| | M Manual Integration used to determine area response | ND Not Detected | PL Permit Limit |
| | R RPD outside accepted recovery limits | RL Reporting Detection Limit | W Sample container temperature is out of limit as sp |
| | J Analyte detected below quantitation limits | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: R232523

| Sample ID: 26031296-001ADUP | SampType: DUP | TestCode: VOC_DW(524) | Units: %Rec | Prep Date: | RunNo: 232523 | | | | | | |
|------------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R232523 | TestNo: E524.2 | Analysis Date: 3/19/2026 | SeqNo: 6107885 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|------------------------------|------|--|-------|--|------|----|-----|--|---|----|--|
| Surr: 1,2-Dichlorobenzene-d4 | 8.64 | | 10.00 | | 86.4 | 70 | 130 | | 0 | 20 | |
| Surr: 4-Bromofluorobenzene | 8.84 | | 10.00 | | 88.4 | 70 | 130 | | 0 | 20 | |

| Sample ID: LCS-R232523 | SampType: LCS | TestCode: VOC_DW(524) | Units: %Rec | Prep Date: | RunNo: 232523 | | | | | | |
|-------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R232523 | TestNo: E524.2 | Analysis Date: 3/19/2026 | SeqNo: 6108629 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|------------------------------|------|--|-------|--|------|----|-----|--|--|--|--|
| Surr: 1,2-Dichlorobenzene-d4 | 9.62 | | 10.00 | | 96.2 | 70 | 130 | | | | |
| Surr: 4-Bromofluorobenzene | 9.97 | | 10.00 | | 99.7 | 70 | 130 | | | | |

| Sample ID: MB-R232523 | SampType: MBLK | TestCode: VOC_DW(524) | Units: %Rec | Prep Date: | RunNo: 232523 | | | | | | |
|------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R232523 | TestNo: E524.2 | Analysis Date: 3/19/2026 | SeqNo: 6108631 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|------------------------------|------|--|-------|--|------|----|-----|--|--|--|--|
| Surr: 1,2-Dichlorobenzene-d4 | 8.94 | | 10.00 | | 89.4 | 70 | 130 | | | | |
| Surr: 4-Bromofluorobenzene | 9.48 | | 10.00 | | 94.8 | 70 | 130 | | | | |

| | | | |
|--------------------|--|----------------------------------|--|
| Qualifiers: | B Analyte detected in the associated Method Blank | E Value above quantitation range | H Holding times for preparation or analysis exceeded |
| | M Manual Integration used to determine area response | ND Not Detected | PL Permit Limit |
| | R RPD outside accepted recovery limits | RL Reporting Detection Limit | W Sample container temperature is out of limit as sp |
| | J Analyte detected below quantitation limits | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: http://www.settek.com

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: R234312

| Sample ID: LCS-R234312 | SampType: LCS | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|-------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | Analysis Date: 4/14/2026 | SeqNo: 6145649 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1-Dichloropropene | 4.86 | 0.500 | 5.000 | 0 | 97.1 | 70 | 130 | | | | |
| 1,2,4-Trimethylbenzene | 4.45 | 0.500 | 5.000 | 0 | 88.9 | 70 | 130 | | | | |
| Benzene | 4.83 | 0.500 | 5.000 | 0 | 96.6 | 70 | 130 | | | | |
| Ethylbenzene | 4.63 | 0.500 | 5.000 | 0 | 92.6 | 70 | 130 | | | | |
| m,p-Xylene | 8.86 | 0.500 | 10.00 | 0 | 88.6 | 70 | 130 | | | | |
| Naphthalene | 4.42 | 0.500 | 5.000 | 0 | 88.4 | 70 | 130 | | | | |
| o-Xylene | 4.61 | 0.500 | 5.000 | 0 | 92.3 | 70 | 130 | | | | |
| Toluene | 4.38 | 0.500 | 5.000 | 0 | 87.5 | 70 | 130 | | | | |
| Vinyl chloride | 3.85 | 0.500 | 5.000 | 0 | 77.0 | 70 | 130 | | | | |
| Surr: 1,2-Dichlorobenzene-d4 | 10.1 | | 10.00 | | 101 | 70 | 130 | | | | |
| Surr: 4-Bromofluorobenzene | 9.72 | | 10.00 | | 97.2 | 70 | 130 | | | | |

| Sample ID: MB-R234312 | SampType: MBLK | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | Analysis Date: 4/14/2026 | SeqNo: 6145651 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1-Dichloropropene | ND | 0.500 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | ND | 0.500 | | | | | | | | | |
| Benzene | ND | 0.500 | | | | | | | | | |
| Ethylbenzene | ND | 0.500 | | | | | | | | | |
| m,p-Xylene | ND | 0.500 | | | | | | | | | |
| Naphthalene | ND | 0.500 | | | | | | | | | |
| o-Xylene | ND | 0.500 | | | | | | | | | |
| Toluene | ND | 0.500 | | | | | | | | | |
| Vinyl chloride | ND | 0.500 | | | | | | | | | |

Qualifiers:

| | | | | | |
|---|--|----|--------------------------------|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946

20-Apr-26

Client: Columbiana County Health District

Project: Extended Sampling

BatchID: R234312

| Sample ID: MB-R234312 | SampType: MBLK | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|------------------------------|--------------------------|------------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | | Analysis Date: 4/14/2026 | SeqNo: 6145651 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|------------------------------|------|--|-------|--|------|----|-----|--|--|--|--|
| Surr: 1,2-Dichlorobenzene-d4 | 9.62 | | 10.00 | | 96.2 | 70 | 130 | | | | |
| Surr: 4-Bromofluorobenzene | 9.22 | | 10.00 | | 92.2 | 70 | 130 | | | | |

| Sample ID: 26040846-013ADUP | SampType: DUP | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|------------------------------------|--------------------------|------------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | | Analysis Date: 4/14/2026 | SeqNo: 6145653 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|------------------------------|------|-------|-------|--|------|----|-----|---|---|----|---|
| 1,1-Dichloropropene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| 1,2,4-Trimethylbenzene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Benzene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Ethylbenzene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| m,p-Xylene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Naphthalene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| o-Xylene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Toluene | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Vinyl chloride | ND | 0.500 | | | | | | 0 | 0 | 20 | H |
| Surr: 1,2-Dichlorobenzene-d4 | 9.31 | | 10.00 | | 93.1 | 70 | 130 | | 0 | 20 | H |
| Surr: 4-Bromofluorobenzene | 9.19 | | 10.00 | | 91.9 | 70 | 130 | | 0 | 20 | H |

| Sample ID: 26040848-001ADUP | SampType: DUP | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|------------------------------------|--------------------------|------------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | | Analysis Date: 4/14/2026 | SeqNo: 6145655 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

Qualifiers:

| | | | | | |
|---|--|----|--------------------------------|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: R234312

| Sample ID: 26040848-001ADUP | SampType: DUP | TestCode: VOC_DW(524) | Units: µg/L | Prep Date: | RunNo: 234312 | | | | | | |
|------------------------------------|--------------------------|------------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234312 | TestNo: E524.2 | Analysis Date: 4/14/2026 | SeqNo: 6145655 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1-Dichloropropene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| 1,2,4-Trimethylbenzene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Benzene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Ethylbenzene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| m,p-Xylene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Naphthalene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| o-Xylene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Toluene | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Vinyl chloride | ND | 0.500 | | | | | | 0 | 0 | 20 | |
| Surr: 1,2-Dichlorobenzene-d4 | 9.15 | | 10.00 | | 91.5 | 70 | 130 | | 0 | 20 | |
| Surr: 4-Bromofluorobenzene | 9.34 | | 10.00 | | 93.4 | 70 | 130 | | 0 | 20 | |

Qualifiers:

| | | | | | |
|---|--|----|--------------------------------|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: http://www.settek.com

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: R234329

| Sample ID: LCS-R234329 | SampType: LCS | TestCode: VOC-MSTR_ | Units: µg/L | Prep Date: | RunNo: 234329 | | | | | | |
|-------------------------------|--------------------------|----------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234329 | TestNo: SW8260 | Analysis Date: 4/14/2026 | SeqNo: 6146209 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 2-Ethylhexyl acrylate | 22.4 | 5.00 | 20.00 | 0 | 112 | 70 | 190 | | | | |
| n-Butyl acrylate | 21.0 | 5.00 | 20.00 | 0 | 105 | 60 | 133 | | | | |
| Surr: 4-Bromofluorobenzene | 50.1 | | 50.00 | | 100 | 70 | 130 | | | | |
| Surr: Dibromofluoromethane | 49.1 | | 50.00 | | 98.2 | 70 | 130 | | | | |
| Surr: Toluene-d8 | 49.5 | | 50.00 | | 98.9 | 70 | 130 | | | | |

| Sample ID: MB-R234329 | SampType: MBLK | TestCode: VOC-MSTR_ | Units: µg/L | Prep Date: | RunNo: 234329 | | | | | | |
|------------------------------|--------------------------|----------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234329 | TestNo: SW8260 | Analysis Date: 4/14/2026 | SeqNo: 6146212 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 2-Ethylhexyl acrylate | ND | 5.00 | | | | | | | | | |
| n-Butyl acrylate | ND | 5.00 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 47.7 | | 50.00 | | 95.5 | 70 | 130 | | | | |
| Surr: Dibromofluoromethane | 49.1 | | 50.00 | | 98.2 | 70 | 130 | | | | |
| Surr: Toluene-d8 | 53.2 | | 50.00 | | 106 | 70 | 130 | | | | |

| Sample ID: 26040882-001DMS | SampType: MS | TestCode: VOC-MSTR_ | Units: µg/L | Prep Date: | RunNo: 234329 | | | | | | |
|-----------------------------------|--------------------------|----------------------------|---------------------------------|-----------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234329 | TestNo: SW8260 | Analysis Date: 4/14/2026 | SeqNo: 6146220 | | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 2-Ethylhexyl acrylate | 21.9 | 5.00 | 20.00 | 0 | 110 | 70 | 190 | | | | |
| n-Butyl acrylate | 21.0 | 5.00 | 20.00 | 0 | 105 | 18.8 | 188 | | | | |
| Surr: 4-Bromofluorobenzene | 49.9 | | 50.00 | | 99.8 | 70 | 130 | | | | |

Qualifiers:

| | | | | | |
|---|--|----|--------------------------------|----|--|
| B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceeded |
| M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| J | Analyte detected below quantitation limits | | | | |

Original



Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 26040946
 20-Apr-26

Client: Columbiana County Health District
Project: Extended Sampling

BatchID: R234329

| Sample ID: 26040882-001DMS | SampType: MS | TestCode: VOC-MSTR_ | Units: µg/L | Prep Date: | RunNo: 234329 | | | | | | |
|-----------------------------------|--------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234329 | TestNo: SW8260 | | Analysis Date: 4/14/2026 | SeqNo: 6146220 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|------|--|-------|--|------|------|-----|--|--|--|--|
| Surr: Dibromofluoromethane | 49.6 | | 50.00 | | 99.2 | 70 | 130 | | | | |
| Surr: Toluene-d8 | 49.2 | | 50.00 | | 98.5 | 46.1 | 154 | | | | |

| Sample ID: 26040882-001DMSD | SampType: MSD | TestCode: VOC-MSTR_ | Units: µg/L | Prep Date: | RunNo: 234329 | | | | | | |
|------------------------------------|--------------------------|----------------------------|--------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: BatchQC | Batch ID: R234329 | TestNo: SW8260 | | Analysis Date: 4/14/2026 | SeqNo: 6146221 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|------|------|-------|---|------|------|-----|-------|------|----|--|
| 2-Ethylhexyl acrylate | 20.2 | 5.00 | 20.00 | 0 | 101 | 70 | 190 | 21.90 | 7.84 | 20 | |
| n-Butyl acrylate | 19.0 | 5.00 | 20.00 | 0 | 95.1 | 18.8 | 188 | 20.99 | 9.86 | 20 | |
| Surr: 4-Bromofluorobenzene | 50.7 | | 50.00 | | 101 | 70 | 130 | | 0 | 20 | |
| Surr: Dibromofluoromethane | 50.3 | | 50.00 | | 101 | 70 | 130 | | 0 | 20 | |
| Surr: Toluene-d8 | 49.3 | | 50.00 | | 98.5 | 46.1 | 154 | | 0 | 20 | |

| | | | | | | |
|--------------------|---|--|----|--------------------------------|----|--|
| Qualifiers: | B | Analyte detected in the associated Method Blank | E | Value above quantitation range | H | Holding times for preparation or analysis exceede |
| | M | Manual Integration used to determine area response | ND | Not Detected | PL | Permit Limit |
| | R | RPD outside accepted recovery limits | RL | Reporting Detection Limit | W | Sample container temperature is out of limit as sp |
| | J | Analyte detected below quantitation limits | | | | |

Original

These commonly used Qualifiers and Acronyms may or may not be present in this report.

Qualifiers

| | |
|--------------|---|
| U | The compound was analyzed for but was not detected above the MDL. |
| J | The reported value is greater than the Method Detection Limit but less than the Reporting Limit. |
| H | The hold time for sample preparation and/or analysis was exceeded. Not Clean Water Act compliant. |
| D | The result is reported from a dilution. |
| E | The result exceeded the linear range of the calibration or is estimated due to interference. |
| MC | The result is below the Minimum Compound Limit. |
| * | The result exceeds the Regulatory Limit or Maximum Contamination Limit. |
| m | Manual integration was used to determine the area response. |
| d | Manual integration in which peak was deleted |
| N | The result is presumptive based on a Mass Spectral library search assuming a 1:1 response. |
| P | The second column confirmation exceeded 25% difference. |
| C | The result has been confirmed by GC/MS. |
| X | The result was not confirmed when GC/MS Analysis was performed. |
| B | The analyte was detected in the Method Blank at a concentration greater than the RL. |
| MB+ | The analyte was detected in the Method Blank at a concentration greater than the MDL. |
| G | The ICB or CCB contained reportable amounts of analyte. |
| QC-/+ | The CCV recovery failed low (-) or high (+). |
| R/QDR | The RPD was outside of accepted recovery limits. |
| QL-/+ | The LCS or LCSD recovery failed low (-) or high (+). |
| QLR | The LCS/LCSD RPD was outside of accepted recovery limits. |
| QM-/+ | The MS or MSD recovery failed low (-) or high (+). |
| QMR | The MS/MSD RPD was outside of accepted recovery limits. |
| QV-/+ | The ICV recovery failed low (-) or high (+). |
| S | The spike result was outside of accepted recovery limits. |
| W | Samples were received outside temperature limits (0° – 6° C). Not Clean Water Act compliant. |
| Z | Deviation; A deviation from the method was performed; Please refer to the Case Narrative for additional information |

Acronyms

| | | | |
|-------------|-------------------------------------|---------------|--------------------------------------|
| ND | Not Detected | RL | Reporting Limit |
| QC | Quality Control | MDL | Method Detection Limit |
| MB | Method Blank | LOD | Level of Detection |
| LCS | Laboratory Control Sample | LOQ | Level of Quantitation |
| LCSD | Laboratory Control Sample Duplicate | PQL | Practical Quantitation Limit |
| QCS | Quality Control Sample | CRQL | Contract Required Quantitation Limit |
| DUP | Duplicate | PL | Permit Limit |
| MS | Matrix Spike | RegLvl | Regulatory Limit |
| MSD | Matrix Spike Duplicate | MCL | Maximum Contamination Limit |
| RPD | Relative Percent Different | MinCL | Minimum Compound Limit |
| ICV | Initial Calibration Verification | RA | Reanalysis |
| ICB | Initial Calibration Blank | RE | Reextraction |
| CCV | Continuing Calibration Verification | TIC | Tentatively Identified Compound |
| CCB | Continuing Calibration Blank | RT | Retention Time |
| RLC | Reporting Limit Check | CF | Calibration Factor |

This list of Qualifiers and Acronyms reflects the most commonly utilized Qualifiers and Acronyms for reporting. Please refer to the Analytical Notes in the Case Narrative for any Qualifiers or Acronyms that do not appear in this list or for additional information regarding the use of these Qualifiers on reported data.



Alliance Technical Group - Akron
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

DATES REPORT

WO#: 26040946
20-Apr-26

Client: Columbiana County Health District

Project: Extended Sampling

| Sample ID | Client Sample ID | Collection Date | Matrix | Test Name | Leachate Date | Prep Date | Analysis Date |
|---------------|------------------|-----------------------|----------------|---|---------------|----------------------|-----------------------|
| 26040946-001A | ES-091 | 4/10/2026 10:20:00 AM | Drinking Water | Synthetic Organic Compounds by GC/ (EPA 525.3) | | 4/14/2026 9:50:00 AM | 4/16/2026 8:28:00 PM |
| 26040946-001B | | | | SVOC by 8270E | | 4/14/2026 9:20:00 AM | 4/15/2026 3:13:00 AM |
| 26040946-001C | | | | VOC-GC/MS (524.2) | | | 4/14/2026 5:52:00 PM |
| 26040946-001D | | | | VOC by GC/MS (8260D) | | | 4/14/2026 10:12:00 PM |
| 26040946-002A | FB-091 | 4/10/2026 10:15:00 AM | | Synthetic Organic Compounds by GC/ (EPA 525.3) | | 4/14/2026 9:50:00 AM | 4/16/2026 9:01:00 PM |
| 26040946-002B | | | | SVOC by 8270E | | 4/14/2026 9:20:00 AM | 4/15/2026 3:47:00 AM |
| 26040946-002C | | | | VOC-GC/MS (524.2) | | | 4/14/2026 6:20:00 PM |
| 26040946-002D | | | | VOC by GC/MS (8260D) | | | 4/14/2026 10:39:00 PM |
| 26040946-003A | Trip Blank | 4/10/2026 | | VOC-GC/MS (524.2) | | | 4/14/2026 6:48:00 PM |
| 26040946-003B | | | | VOC by GC/MS (8260D) | | | 4/14/2026 11:07:00 PM |

Original



3310 Win Street Cuyahoga Falls, Ohio 44223 (330) 253-8211

Analysis Request / Chain of Custody

https://www.alliancecg.com/services/environmental https://testek.com/

| | |
|----------|---|
| LAB NO.: | For Alliance Technical Group, LLC-Akron use only 26040946 |
|----------|---|

| Client Name CCHD | | Project Identification Extended Sampling Program | | Analytical Parameters and Methods Requested | | | | | | | | | | | | | | | | |
|---|-----------------|--|----------------|---|---|---|---|---------------------------------|--|---|---|--------------------------------------|----------------------------------|--|------------------------------|---------------------------|--|--|--|--|
| Client Street Address 7360 SR 45 | | [REDACTED] | | Grab Sample | Composite Sample | Matrix: S = Solids, SL = Sludges, L = Liquids, O = Oil, A = Air, NPW = Non-Potable Water, DW = Drinking Water | Preservation: 1) HNO3; 2) H2SO4; 3) HCl; 4) Zinc Acetate; 5) NaOH; 6) ZDA; 7) none; 8) other (specify in comment) | Number of Containers per Sample | [Empty grid for analytical parameters] | | | | | | | | | | | |
| City Lisbon OH 44432 | | [REDACTED] | | | | | | | [Empty grid for analytical parameters] | | | | | | | | | | | |
| Client Phone 330-424-0272 | | CCHD | | | | | | | [Empty grid for analytical parameters] | | | | | | | | | | | |
| Contact Person Kevin Summerville | | Quote Number | | | | | | | [Empty grid for analytical parameters] | | | | | | | | | | | |
| Client Email Address ksummerville@columbiana-health.org | | PWS ID | | Facility ID | | [Empty grid for analytical parameters] | | | | | | | | | | | | | | |
| Sampled By (Print Name and Provide Signature) Emma Gray | | Reporting/Accreditation Requirements: <input type="checkbox"/> Ohio VAP <input type="checkbox"/> Ohio EPA Pb, Cu <input type="checkbox"/> Drinking Water Compliance <input type="checkbox"/> BUSTR | | [Empty grid for analytical parameters] | | | | | | | | | | | | | | | | |
| For D.W. only, results to be reported to state by lab? <input type="checkbox"/> Yes <input type="checkbox"/> No | | Other Compliance (List State/ Program): | | [Empty grid for analytical parameters] | | | | | | | | | | | | | | | | |
| # | Sample Point ID | Sample Identification | Date Collected | Time Collected | Grab Sample | Composite Sample | Matrix | Preservation | Number of Containers per Sample | 524 | 8270 | 525 | 8260 | For DW Only: Special Compliance or Routine (S/R) | | | | | | |
| | SS-091 | Kitchen Sink | 4/10/26 | 10:20 | ✓ | | DW | 8 | 10 | X | X | X | X | | | | | | | |
| | FB-091 | FB | 4/10/26 | 10:15 | X | | DW | 8 | 10 | X | X | X | X | | | | | | | |
| Relinquished by: | | Date | Time | Received by: | Date | Time | Notes / Comments: | | | | | | | | | | | | | |
| Emma Gray | | 4/15/26 | 7:58A | Luelyn | 4-13-26 | 7:58 | 524: HCL, 8260: HCL, 525: Sodium Sulfite | | | | | | | | | | | | | |
| Luelyn | | 4-15-26 | 15:19 | | | | Sufficient volume for analysis? <input checked="" type="radio"/> YES <input type="radio"/> NO Cooler? <input checked="" type="radio"/> YES <input type="radio"/> NO <input type="radio"/> N/A | | | | | | | | | | | | | |
| Received at ATG-Akron by: | | Date | Time | Carrier | RUSH Requested: ___ Day(s) <small>Please provide advanced notice of rush requests whenever possible.</small> | | | Receipt Temperature: | | Cooler Seals? | Sample Seals? | Ice Present? | | | | | | | | |
| Luelyn | | 4/13/26 | 15:15 | ATG | | | | 1.5 °C | | <input checked="" type="radio"/> INTACT | <input checked="" type="radio"/> INTACT | <input checked="" type="radio"/> YES | <input type="radio"/> NOT INTACT | <input type="radio"/> NOT INTACT | <input type="radio"/> MELTED | <input type="radio"/> N/A | | | | |

1.6 - 0.1 = 1.5
C.S. INTACT 4/13/26






Alliance Technical Group - Akron
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

Sample Log-In Check List

Client Name: **COL-OH-44432**

Work Order Number: **26040946**

RcptNo: **1**

| | | | |
|---------------|---------------------|-----------------------------|--|
| Logged by: | Nick Rigby | 4/13/2026 3:15:00 PM |  |
| Completed By: | Nick Rigby | 4/13/2026 3:35:26 PM |  |
| Reviewed By: | Holly Florea | 4/14/2026 9:12:20 AM |  |

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Alliance

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: 4/13/2026 Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

| | | | |
|----------------------|----------------------|------|---|
| Person Notified: | <input type="text"/> | Date | <input type="text"/> |
| By Whom: | <input type="text"/> | Via: | <input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person |
| Regarding: | <input type="text"/> | | |
| Client Instructions: | <input type="text"/> | | |

18. Additional remarks:

Cooler Information

| Cooler No | Temp °C | Condition | Seal Intact | Seal No | Seal Date | Signed By |
|-----------|---------|-----------|-------------|---------|-----------|-----------|
| 1 | 1.5 | Good | Yes | | 4/13/2026 | |